



# **Binghamton Fire Bureau**

## **Operating Permit Appendix A**

### **Hazardous Materials Storage**

### **And Tank Installation/Removal**

**Directions: Read the requirements listed below for Hazardous Materials Storage. If you have any questions, please contact the Fire Marshal's Office at (607) 772-7123.**

An Operating Permit is required when (1) any hazardous material included in any category listed in tables 2703.1.1(1), 2703.1.1(2), 2703.1.1(3) or 2703.1.1(4) of the *Fire Code of New York State* is manufactured, stored or handled and (2) the quantity of such hazardous material exceeds the quantity listed in the applicable table.

This would include any building that is (whole or in part) a Group H occupancy, is a pre-existing, non-conforming hazardous occupancy, or has outdoor use manufacture, and/or storage of materials that exceed the tables for physical and/or health hazard.

This type of Operating Permit will not be issued until an inspection has been performed and establishes to the satisfaction of the Binghamton Fire Marshal's Office that the requirements of the *Fire Code of New York State* are satisfied.

These requirements include the provisions of Chapter 27 of the *Fire Code of New York State* as well as any specialized manufacture, use, storage requirements within Chapters 27-42 of the *Fire Code of New York State*.

A previous fire safety inspection cannot suffice for an Operating Permit application inspection.

If necessary, tests to verify compliance with the *Fire Code of New York State* must be performed and the reports of such tests must be provided to the Binghamton Fire Marshal's Office. Tests and reports needed to verify compliance with the Fire Code of New York State vary from product to product. Tests and reports may include:

- Verification of inspection of fire protection systems and emergency alarm systems
- Verification of inspection of storage cylinders, tanks, or containers
- Completing of the Hazardous Materials Reporting Form, as required by General Municipal Law 209-u (available from OFPC at <http://www.dos.state.ny.us/fire/pdfs/forms/hm209u.pdf>)
- Presentation of Material Safety Data Sheets for the product(s) requiring permits
- Affidavits that the regulated party is in conformance with other State Agencies (Environmental Conservation, Health, Labor)



# Binghamton Fire Bureau Operating Permit Appendix A Storage Tank Installation/Removal

**Directions: Complete this Appendix and return with completed Application to:**

Binghamton Fire Bureau  
Office of the Fire Marshal  
38 Hawley St, 3<sup>rd</sup> floor  
Binghamton, NY 13901

**If you have any questions, please contact the Fire Marshal's Office at 772-7123.**

Tank #	Capacity (gal)	Contents	Tank Type	Aboveground/Underground	Installing/Removing

Property Location: \_\_\_\_\_

Property Tenant: \_\_\_\_\_ Phone #: \_\_\_\_\_

Contractor: \_\_\_\_\_

Address: \_\_\_\_\_

City/State/Zip: \_\_\_\_\_

Phone #: \_\_\_\_\_

Signature of Tenant or Contractor: \_\_\_\_\_

Printed Name of person signing above: \_\_\_\_\_