



Binghamton Fire Bureau

Operating Permit Appendix E

Requirements for Gases

Directions: Read the requirements listed below. If you have any questions, please contact the Fire Marshal's Office at (607) 772-7123.

REQUIREMENTS FOR THE STORAGE USE AND HANDLING OF COMPRESSED AND LIQUEFIED PETROLEUM FLAMMABLE GASES

1. A permit must be obtained, from the Fire Marshal, for all systems connected to liquefied petroleum or other compressed flammable gas container(s) and/or the storage thereof. Plans of the installation shall accompany request for such a permit.
2. The Chief of the Fire Department, or the Fire Marshal, may restrict the storage of compressed or liquefied petroleum flammable gases, within the City of Binghamton, to any amount which they deem safe.
3. Cylinders and regulating equipment shall be located outside of buildings in well ventilated steel cabinets. Such equipment must also be protected from tampering and exposure to the equipments.
4. Compressed gas cylinders, in use or storage, shall be secured to prevent falling or upset.
5. Storage of cylinders located in areas subject to vehicular traffic shall be protected from damage from same.
6. Compressed gas cylinders, when not in use, shall have protective caps in place over the valve assembly.
7. Cylinders, pressure vessels or other containers shall be clearly identified as to the gas contained therein.
8. For information on Propane Exchange cabinets, contact the Fire Marshal's Office at (607) 772-7123.

Reason for not using natural gas? (If applicable): _____

To be used for: _____

of Cylinders requested: Size of each cylinder: _____

of Cylinders to be in use at one time: _____

of Spares on Site: _____

Proposed Supplier: _____

Supplier Phone #: _____

For a complete listing of all requirements see:

- A. City of Binghamton code of ordinances – Section 8-50
- B. Title 9, NYCRR
- C. Generally accepted reference standards listed in title 9, NYCRR